

१. शिलबन्दी दरभाउपत्र आवहान सम्बन्धी सूचना



जिल्ला अस्पताल, भोजपुर

शिलबन्दी दरभाउपत्र आवहान सम्बन्धी सूचना नं. ०४/०७७-०७८

सूचना प्रकाशन मिति:- २०७७/०७/०३

१. यस जिल्ला अस्पताल भोजपुरको आ.व. २०७७/०७८ को स्वीकृत वार्षिक कार्यक्रम अनुसार अस्पतालको लागि आवश्यक तपशीलमा उल्लेखित सामग्रीहरू शिलबन्दी दरभाउपत्रको माध्यमबाट खरीद गर्नुपर्ने भएकोले सम्बन्धित क्षेत्रमा काम गर्न ईजाजत प्राप्त ईच्छुक फर्म, संस्था वा सप्लायर्सबाट शिलबन्दी दरभाउपत्र आवहान गरीएको छ ।
२. खरीद गरिने तपशीलमा उल्लेखित सामग्रीहरूको स्पेसिफिकेशन र परिमाण दरभाउपत्र सम्बन्धी कागजातमा उल्लेख भएबमोजिम हुनेछ ।
३. ईजाजत प्राप्त उत्पादक, फर्म, कम्पनी वा सप्लायर्सबाट सूचना प्रकाशित भएको मितिले १५ (पन्ध्र) औं दिन अर्थात् २०७७/०७/१७ गतेसम्म कार्यालय समय भित्र तोकिएको दस्तुर (फिर्ता नहुने गरी) तिरी दरभाउपत्रदाता वा निजको अधिकृत प्रतिनिधिले दरभाउपत्र फारम यस कार्यालय, जिल्ला प्रशासन कार्यालय र कोष तथा लेखा नियन्त्रक कार्यालय, भोजपुरमा निवेदन पेश गरी खरीद गर्न सकिनेछ र खरीद गरेको शिलबन्दी दरभाउपत्र मिति २०७७/०७/१८ गते बिहान १२:०० बजे सम्म यस जिल्ला अस्पताल भोजपुरमा दाखिल गरिसक्नुपर्नेछ । दाखिल हुन आएका शिलबन्दी दरभाउपत्र सोही दिन दिनको २:०० बजे जिल्ला अस्पताल भोजपुरमा खोलीनेछ ।
४. प्रत्येक ठेक्का नं को फरक फरक दरभाउपत्र खरीद गरी पेश गर्नुपर्नेछ ।
५. दरभाउपत्र फारम खरीद गर्नका लागि पेश गरिने निवेदनमा रु ११.००१- को टिकट टाँस गरी नेपाली नागरिकताको प्रतिलिपी, आ.व. २०७७/०७८ का लागि नविकरण गरिएको उत्पादक, फर्म, कम्पनी वा सप्लायर्सको दर्ता प्रमाण पत्र, व्यवसाय प्रमाण पत्र, आयकर प्रमाण पत्र, स्थायी लेखा नं, मूल्य अभिवृद्धि कर दर्ता प्रमाण पत्र र आ.व. ०७६/०७७ को कर चुक्ता प्रमाण पत्रको प्रतिलिपी अनिवार्य संलग्न राख्नुपर्नेछ ।
६. दरभाउपत्रदाताले दरभाउपत्र खरीद गर्दा सम्बन्धित कार्यालयको अधिकार प्राप्त कर्मचारीको दस्तखत, कार्यालयको छाप लागेको दरभाउपत्र खरीद गर्नुपर्नेछ । दस्तखत नभएको र कार्यालयको छाप नभएको दरभाउपत्र कुनै हालतमा मान्य हुने छैन ।
७. दरभाउपत्र दर्ता गर्दा प्रोपाईटर वा आधिकारिक प्रतिनिधिले सहिछाप गरेको र शिलबन्दी भएको हुनुपर्नेछ ।
८. दरभाउपत्र फारम दस्तुर रु.१०००१- रहेको छ ।
९. शिलबन्दी दरभाउपत्रको मान्य अवधि दरभाउपत्र खोलीएको मिति देखि गणना हुने गरी ४५ दिनको हुनेछ ।
१०. तपशीलमा उल्लेख गरिएबमोजिमको दरभाउपत्र जमानत बापत यस कार्यालयको राष्ट्रिय बाणिज्य बैंक, भोजपुरमा रहेको प्रदेश धरौटी खाता ख २३, खाता न. २०४०१००२०२०३०००० मा नगद जम्मा गरेको सक्कल भौचर वा बाणिज्य बैंकबाट ७५ दिनको मान्य अवधि रहने गरी जारी भएको बैंक जमानत शिलबन्दी दरभाउपत्रसाथ पेस गर्नुपर्नेछ ।

Dr. Amitesh Raj Pandey
MBBS/ MDGP & EM
NMC No. 14030



११. दर्ता भएका शिलबन्दी दरभाउपत्रहरू कार्यालय प्रतिनिधीहरू दरभाउपत्र दाताहरूको रोहवरमा खोलिनेछ । दरभाउपत्रदाता वा निजका प्रतिनिधी उपस्थित नभएमा पनि दरभाउपत्र खोल्न बाधा पर्ने छैन ।

१२. दरभाउपत्र विक्रि गर्ने अन्तिम दिन, शिलबन्दी दरभाउपत्र दर्ता गर्ने र खोलने दिन सार्वजनिक विदा परेमा उक्त कार्यहरू विदाको लगत्तै पछिको कार्यालय खुलेको दिन सोहि समयमा हुनेछ ।

१३. शिलबन्दी दरभाउपत्रमा कबोल गरेको दररेट अडक र अक्षर दुवैमा प्रष्ट रूपमा लेखिएको हुनुपर्नेछ । अडक र अक्षरमा फरक परेमा अक्षरलाई मान्यता दिईनेछ । केरमेट भएको ठाउँमा दस्तखत गरेको हुनुपर्नेछ ।

१४. ढिलो गरी प्राप्त अर्थात म्याद नाघी आएको र रीत नपूगेको शिलबन्दी दरभाउपत्र उपर कुनै कारबाही गरिने छैन ।

१५. एक फर्म, संस्था वा कम्पनीको नाममा खरीद गरेको दरभाउपत्र फाराम अर्को फर्म, संस्था वा कम्पनीको नामवाट दाखिला गर्न पाईने छैन ।

१६. संज्ञौता अवधि भित्र कुनै प्रकारको मूल्य वृद्धिलाई स्वीकार गरिने छैन ।

१७. शिलबन्दी दरभाउपत्र स्वीकृत गर्ने, रद्द गर्ने वा आंशिक रूपमा स्वीकृत गर्ने वा नगर्ने सम्पुर्ण अधिकार खरिद कर्तामा निहित रहनेछ ।

१८. सार्वजनिक खरिद नियमावली, २०६४ को नियम ४० (ड) अनुसार दरभाउपत्रदाताले खरीद कारबाहीमा भाग लिन अयोग्य नभएको, प्रस्तावित खरीद कारवाहीमा आफ्नो स्वार्थ नबाझिएको र सम्बन्धित पेशा वा व्यवसाय सम्बन्धी कसुरमा आफुले सजाय नपाएको भनी लिखित रूपमा स्वयंले घोषणा गरेको पत्र पेश गर्नुपर्नेछ ।

१९. यस सूचनामा छुट हुन गएका अन्य कुराहरूको हकमा सार्वजनिक खरिद ऐन, २०६३ र सार्वजनिक खरिद नियमावली, २०६४ तथा प्रचलित ऐन, नियम र कानुन अनुसार हुनेछ ।

२०. सूचना सम्बन्धी अन्य कुराहरू बुझ्नुपरेमा यस कार्यालयको website: dhbhp.p1.gov.np मा log in गरी हेर्न सकिनेछ साथै कार्यालय समयभित्र जिल्ला अस्पताल भोजपुरको सम्पर्क फोन नं : ०२९-४२०७४९, मो.नं. ९८५२०५२७४९, ईमेल:- hospitalbhp@gmail.com मा सम्पर्क राख्न सकिनेछ ।

२१. दरभाउपत्र फाराम खरीद गर्न फारम दस्तुर प्रदेश लेखा ईकाई कार्यालय (STSA) भोजपुरको कार्यालय कोड नं ३५००४०७०२१, राष्ट्रिय बाणिज्य बैंकमा रहको खाता नं. १०००१००२०१०१०००१, कार्यालयको नाम जिल्ला अस्पताल, भोजपुर, राजस्व शिर्षक नं. १४२२९ मा जम्मा गरी जम्मा गरेको भौचर पेश गर्नुपर्नेछ ।

तपशील

क्र.सं.	ठेक्का नं	कामको विवरण	कुल लागत अनुमान	दरभाउपत्र जमानत रकम	दरभाउपत्र दस्तुर
१.	३/०७७-०७८	ULTRA SOUND MACHINE	२८,५८,९००/-	७५,०००/-	१०००/-
२.	४/०७७-०७८	GENERATOR SET (DIESEL 63KVA)	१२,००,०००/-	३०,०००/-	१०००/-
३.	५/०७७-०७८	संक्रमण रोकथाम तथा सरसफाईका सामग्रीहरू खरीद	९,९७,३३८/-	२०,०००/-	१०००/-

Dr. Amitesh Raj Pandey
MBBS/ MDG
NMC No. 1



TECHNICAL SPECIFICATION FOR Generator Set Diesel 63 KVA

S.N.	Purchaser's Specifications	Bidder's Compliance Sheet		
		Yes/No	Page No. in Catalogue	Remarks
	Generator Set Diesel 63 KVA(Bhojpur DH)			
	Manufacturer			
	Brand			
	Type / Model			
	Country of Origin			
1	Description of Function			
1.1	Diesel driven generator set, Air cooled or water cooled and skid mounted, capable of delivering up to 63 kVA at 1500 rpm			
2	Operational Requirements			
2.1	A complete diesel generator set including the diesel engine, alternator, control panel, automatic starting equipment, fuel tank, battery and all other accessories for autonomous operation.			
3	System Configuration			
3.1	Generator Set Diesel 63KVA, Three Phase complete unit and with complete accessories.			
4	Technical Specifications			
4.1	Rated power:			
	63 kVA, 50 kW, Power factor (Cos. phi = 0.8), 400 V, 3-phase, 50 Hz at NTP (Normal Temperature and Pressure).			
4.2	Engine:			
	Heavy duty diesel engine, with the following characteristics:			
	Should have Water-cooled or Air cooled and tropical radiator			
	Synchronous speed: Minimum 1500 rpm			
	Mechanical speed governor			
	Heavy duty air cartridge filter			
	Cartridge oil filter			
	Industrial silencer			
	Exhaust with suitable flexible piping			
	Automatic electric starter including batteries, leads and automatic battery charging equipment.			
	Fuel: At 100% load :16 l/hr , At 75% load: 12l/hr, At 50% load :8l/hr or less.			
	Battery: Lead acid battery with nominal capacity min: 75 AH with suitable voltage and current rating as required by the starter.			
4.3	Fuel tank:			
	Fuel tank : Approx 150 l			
	Suitable piping must be provided for connecting the tank to the engine as well as for filling the tank			
	Fuel level indicator must be placed conveniently on the panel board			
4.4	Alternator:			
	Synchronous and brushless			
	Automatic fast voltage regulator, maintaining the output within 2 % under normal conditions			
	Efficiency: 0.8pf , not less than 90%			
4.5	Panel board:			
	Made of steel sheets of appropriate thickness subjected to anti-oxidizing treatment and covered with epoxy resin with suitable protection factor.			
	The panel board comprises:			
	Automatic main circuit breaker			
	Change over switch with positions for "MAINS" - "OFF" - "GENERATOR".			
	Key to start and stop the unit			
	Emergency stop button			
	Set-point for speed/governor control			
	Set-point for voltage control			

Dr. Amitesh Raj Pandey
 MBBS/ MDGP & EM
 NMC No. 14030




S.N.	Purchaser's Specifications	Bidder's Compliance Sheet		
		Yes/No	Page No. in Catalogue	Remarks
	Generator Set Diesel 63 KVA(Bhojpur DH)			
	Meters for: Volts (with selector switch to show phases to zero, and phase to phase voltages), amperes (three meters or with selector switch to show current in all three phases), frequency, running hours counter			
	Acoustic and visible alarms for critical parameters including high engine temperature low oil pressure and low fuel must be provided.			
4.6	Protection:			
	The generator set must be equipped with automatic shutdown equipment if fatal parameters are exceeded including low oil pressure, high engine temperature and over-speed.			
4.7	Mounting:			
	The engine and the alternator must be connected with a heavy-duty elastic coupling and must be mounted on a common rigid base frame with anti-vibration dampers and lifting eyes flexible for transportation Engine, alternator and panel must be one integrated unit mounted on skids.			
4.8	Connection to ground:			
	The generator is supplied with connection to ground system comprising low resistance rod(s), terminals, cables, etc.			
4.9	The generator set mounted in a sound attenuated and weather protective canopy to reduce the noise level down to 70 dB (A) at a distance of 7 metres.			
4.1	The generator must have Automatic Mains Failure (AMF) system.			
5	Accessories, spares and consumables			
5.1	Accessories:			
	Engine coolant/antifreeze liquid for the first installation			
	Tools kit including pipe spanners for injectors, etc.			
	Oil and air filter cartridges			
	Two full sets of v-belts and a full set of cylinder head gaskets			
	A full set of replacement switches/sensors for detection of fatal parameters (low oil pressure, high engine temperature, belt failure, etc.).			
5.2	All standard accessories, consumables and parts required to operate the equipment, including all standard tools and cleaning and lubrication materials, to be included in the offer. Bidders must specify the quantity of every item included in their offer (including items not specified above).			
6	Operating Environment			
6.1	The system offered shall be designed to be stored and to operate normally under the conditions of the purchaser's country. The conditions include Power Supply, Climate, Temperature, Humidity, etc.			
6.2	Power supply: 400V 50 Hz AC Three phase fitted with appropriate plugs.			
7	Standards and Safety Requirements			
7.1	Must submit ISO 9001 certificate AND			
7.2	Must be USFDA or CE or UL or TUV or ARAI (Automotive Research Association of India) or any other relevant national / international standard approved product.			
8	User Training			
8.1	Must provide user training (including how to use and maintain the equipment).			
9	Warranty			

Dr. Amitesh Raj Pandey
 MBBS/ MDG
 NMC No. 14000



S.N.	Purchaser's Specifications	Bidder's Compliance Sheet		
		Yes/No	Page No. in Catalogue	Remarks
	Generator Set Diesel 63 KVA(Bhojpur DH)			
9.1	Comprehensive warranty for 2 years after acceptance.			
10	Maintenance Service During Warranty Period			
10.1	During the warranty period supplier must ensure planned preventive maintenance (PPM) and corrective/breakdown maintenance whenever required.			
11	Installation and Commissioning			
11.1	The bidder must arrange for the equipment to be installed and commissioned by certified or qualified personnel; any prerequisites for installation to be communicated to the purchaser in advance, in detail.			
12	Documentation			
12.1	User (Operating) manual in English			
12.2	Service (Technical / Maintenance) manual in English			
12.3	List of important spare parts and accessories with their part number and costing.			
12.4	Certificate of calibration and inspection from factory.			
	Bidder must completely fill the Technical Specification Form (TSF). Only Yes/No/All complies should not be written. Page number in the catalogue of all the required parameters must be clearly mentioned and highlighted. Failure in doing so may lead to rejection of bid from technical committee.			


Dr. Amitesh Raj Pandey
 MBBS/MDGP & EM
 NMC No. 20000